

## *Annual Drinking Water Quality Report for 2018*

Town of Greenport

600 Town Hall Drive, Hudson, NY 12534

Greenport South Wells (Public Water Supply Identification Number NY1000238)

Mt. Ida for Columbia Country WD#1 (Public Water Supply Identification Number NY1030073)

### **INTRODUCTION**

To comply with State regulations, the Town of Greenport will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, your drinking water met all State drinking water health standards. This report is a snapshot of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to New York State standards. Our constant goal is and always has been, to provide to you a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and to protect our water resources. If you have any questions concerning this report or concerning your drinking water please contact: *Mr. John E. Mokszycki, Water & Wastewater Superintendent, Town of Greenport Water Department, 600 Town Hall Drive, Hudson, NY 12534; Telephone # (518) 828-3400.* For questions concerning the Mt. Ida Water System please contact: *Mr. Robert Pinto, Facilities Supervisor, 401 State Street, Hudson, NY 12534, Telephone # (518) 828-0871.* We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the 1<sup>st</sup> Wednesday of each month, 7:00 PM at the Greenport Town Hall, Town Hall Drive, Hudson, NY 12534. Telephone number (518) 828-4656

### **WHERE DOES OUR WATER COME FROM?**

The Town of Greenport draws its water from a ground water source. Groundwater or well water is stored below the surface of the earth in deep, porous rocks called "aquifers." Groundwater is purified naturally as it filters through layers of soil, clay, rock and sand. This process, known as "percolation" takes years to complete. As a result, groundwater requires less treatment than surface water. Greenport's main source of water derives from a 6-acre parcel of land located along Kashway Creek, known as the South Wells. At this site there are three drilled wells, approximately 300 feet deep, producing approximately 1,450 gallons per minute. We also own 71 acres of property purchased from Andrew Wyda that connects to the six acre parcel where the South Wells are located. The property extends west from the South Wells property to Middle Road. The property was purchased for future well development and to protect the South Wells source.

Gaseous chlorine is added to the water, which is used for disinfection to protect against contamination from harmful bacteria and other organisms. We utilize a device called a "chlorinator" consisting of a combination of pressure reducing valves and mechanical diaphragms for measuring the rate of flow of the chlorine gas, and making an aqueous solution of the gas so it can be injected into the water. Chlorine is injected into a 9,000 gallon storage pit into which the well pumps discharge. When a well pump is called for, water from the discharge end of the pump creates a vacuum, drawing chlorine from the "chlorinator" which is connected to a 100-pound chlorine cylinder. This water is discharged into the pump pit and then into the distribution system and subsequently pumped to the 2 million gallon bubble tank, the Joslen Boulevard Tank (170,000 gallons) and the Ravish Road tank (1.3 million gallons) through the low level transfer pumps. The storage tank located at Ten Broeck Lane (145,000) gallons has been out of service. Two booster pump stations have been added to service customers that were previously serviced by the Ten Broeck Lane high level pumps. The Mt. Ida water system which uses a source located in North Claverack along Route 9H on 65 acres has been upgraded to serve the Commerce Park only. Although run as a separate system, it is connected to Greenport's main supply, so that in an emergency either source can be utilized. The same method is used to add the gaseous chlorine as is used for the South Wells. Chlorine is added to the water as it is pumped into the 3000 gallon pressure tank. The chlorinated water is then pumped into the distribution system.

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it

dissolves naturally-occurring minerals and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and EPA prescribe regulations, which limit the amount of certain contaminants in water, provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

#### **FACTS AND FIGURES**

The Greenport Public Water Supply provides water through 1,253 service connections to a population of approximately 4,400 people. Our average daily demand is 662,700 gallons. Our single highest day was 953,000 gallons. In 2018 the South Wells System pumped 241,690,000 gallons of water and 225,088,000 gallons of water were recorded as metered usage by customers. As a result, 6.87% or 16,602,000 gallons was lost in the transmission and distribution system. This unaccounted water was used for fire fighting purposes, distribution system leaks and unauthorized use. The charge for water within the Town of Greenport Water District for 2018 is \$2.53/1000 gallons. For a \$150,000 home using 36,000 gallons/year the water bill would be \$284.40

The Mt. Ida System provides water through 21 service connections to a population of approximately 450 people. Our average daily demand is 20,700 gallons. Our single highest day was 31,000 gallons.

#### **ARE THERE CONTAMINANTS IN OUR DRINKING WATER?**

In accordance with State regulations, the Greenport Public Water Supply routinely monitors your drinking water for numerous contaminants. We test your drinking water for inorganic contaminants, radiological contaminants, lead and copper, nitrate, haloacetic acids, trihalomethanes volatile organic contaminants, and synthetic organic contaminants. In addition, we test (5 samples from the South Wells and 1 sample from Mt. Ida) for coliform bacteria each month. The table presented below depicts which contaminants were detected in your drinking water. The State allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old. For a listing of the parameters we analyzed that were not detected along with the frequency of testing, for compliance with the NYS Sanitary Code, see Appendix A.

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily pose a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the New York State Department of Health or the Columbia County Health Department (518) 828-3358.

#### **WHAT DOES THIS INFORMATION MEAN?**

As you can see by the tables on pages 4 and 5, the Greenport South Wells and Mt. Ida System had no violations. We have learned through our monitoring and testing that some contaminants have been detected; however, these compounds were detected below New York State requirements. MCL's are set at very stringent levels. To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

#### **IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?**

During 2018, our system was in compliance with applicable State drinking water operating, monitoring and reporting requirements.

#### **DO I NEED TO TAKE SPECIAL PRECAUTIONS?**

Although our drinking water met or exceeded state and federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbiological pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

#### **INFORMATION ON LEAD**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Town of Greenport is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>

#### **WHAT IS THE SOURCE WATER ASSESSMENT PROGRAM (SWAP)?**

To emphasize the protection of surface and ground water sources used for public drinking water, Congress amended the Safe Drinking Water Act (SDWA) in 1996. The amendments require that New York State Department of Health's Bureau of Public Water Supply Protection is responsible for ensuring that source water assessments are completed for all of New York's public water systems.

A source water assessment provides information on the potential contaminant threats to public drinking water sources:

- ◆ each source water assessment will: determine where water used for public drinking water comes from (delineate the source areas)
- ◆ Inventory potential sources of contamination that may impact public drinking water sources
- ◆ Assess the likelihood of a source water area becoming potential contaminated

A SWAP summary for our water supply is attached to this report.

#### **WATER CONSERVATION TIPS**

The Greenport Public Water Supply encourages water conservation. There are a lot of things you can do to conserve water in your own home. Conservation tips include:

- ◆ Only run the dishwasher and clothes washer when there is a full load
- ◆ Use water saving showerheads
- ◆ Water gardens and lawn for only a couple of hours after sunset
- ◆ Install faucet aerators in the kitchen and the bathroom to reduce the flow from 4 to 2.5 gallons per minute
- ◆ Check faucets, pipes and toilets for leaks and repair all leaks promptly
- ◆ Take shorter showers

#### **SOURCE WATER RESTRICTIONS**

Weil #1 has failed and removed from service

#### **CAPITAL IMPROVEMENTS**

There were not major capital improvements made during 2018.

#### **CLOSING**

Thank you for allowing us to continue providing your family with clean, quality water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit our customers. We ask that all our customers help us protect our water sources. Please call our office if you have questions.

Contaminant	Violation Y/N	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b> (sample data 4/5/17 unless otherwise noted)						
Arsenic	N	1.3	ppb	N/A	10	Naturally occurring
Chloride	N	85.8	ppm	N/A	250	Geology; Naturally occurring
Copper (samples from 8/19-8/23/17)	N	0.12 <sup>1</sup>	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Range of copper concentrations		ND-0.24				
Fluoride	N	120	ppb	N/A	2200	Erosion of natural deposits
Iron	N	447 <sup>2</sup>	ppb	N/A	300	Geology; Naturally occurring
Lead (samples from 8/19-8/23/17)	N	2 <sup>3</sup>	ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits
Range of lead concentrations		ND-10				
Manganese	N	133 <sup>3</sup>	ppb	N/A	300	Geology; Naturally occurring
Nickel	N	2.5	ppb	N/A	100	Discharge from steel/metal factories
pH	N	7.21	units		6.5-8.5	
Sodium <sup>4</sup>	N	39.4	ppm	N/A	N/A	Geology; Road Salt
Sulfate	N	110	ppm	N/A	250	Geology;
Zinc	N	7.5	ppb	N/A	5000	Galvanized pipe; corrosion inhibitor
<b>Microbiological Results</b>						
Total Coliform (sample from 12/5/18)	N	1 positive sample	N/A	0	2 or more positive samples in 1 month	Naturally present in the environment
<b>Radiological Contaminants</b> (sample from 3/7/18)						
Radium 228	N	1.57	pCi/l	0	5	Erosion of natural deposits
<b>Disinfection Byproducts</b> (samples from 9/12/18)						
TTHM [Total Trihalomethanes]	N	14.3	ppb	0	80	By-product of drinking water chlorination
HAA5 [Haloacetic Acids]	N	11	ppb	N/A	60	By-product of drinking water chlorination
Chlorine (average)	N	0.36	ppm	MRDLG	MRDL	Used in the treatment and disinfection of drinking water
Range of chlorine residuals (based on daily testing)		0.01 - 0.78		N/A	4	

**NOTES-**

- The level presented represents the 90<sup>th</sup> percentile of 20 test sites. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90<sup>th</sup> percentile is equal to or greater than 90% of the copper values detected at your water system. In this case, 20 samples were collected at your water system and the 90<sup>th</sup> percentile value was the 18<sup>th</sup> sample with the third highest value (level detected 0.15 mg/l). The action level for copper was not exceeded at any of the sites tested.
- If iron and manganese are both present a total concentration of 500 ppb. Higher levels may be allowed by the when justified by the supplier of water.
- The level presented represents the 90<sup>th</sup> percentile of 20 test sites. The action level for lead was not exceeded at any of the 20 sites tested.
- Water containing more than 20 mg/l should not be consumed by persons on severely restricted sodium diets
- A violation occurs when a total coliform positive sample is positive for *E. Coli* and a repeat total coliform sample is positive or when a total coliform positive sample is negative for *E. coli* but a repeat total coliform sample is positive and the sample is also positive for *E. coli*.

*Non-Detects (ND)* - laboratory analysis indicates that the constituent is not present.

*Parts per million (ppm) or Milligrams per liter (mg/l)* - one part per million corresponds to one minute in two years or a single penny in \$10,000.

*Parts per billion (ppb) or Micrograms per liter* - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

*Picocuries per liter (pCi/L)* - picocuries per liter is a measure of the radioactivity in water.

*90<sup>th</sup> Percentile Value*- The values reported for lead and copper represent the 90<sup>th</sup> percentile. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90<sup>th</sup> percentile is equal to or greater than 90% of the lead and copper values detected at your water system

*Action Level* - the concentration of a contaminant, which, if exceeded, triggers treatment, or other requirements, which a water system must follow.

*Maximum Contaminant Level* - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

*Maximum Contaminant Level Goal* The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

*Maximum Residual Disinfectant Level (MRDL)*: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

*Maximum Residual Disinfectant Level Goal (MRDLG)*: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination

*N/A-Not applicable*

Asbestos	Every 9 years, 3/4/15 <b>Non-Detect</b>		<b>POC's (Volatile Organic Compounds)</b> Trans-1,3-Dichloropropene	
Antimony	Monitoring requirement is 1 sample every 3 years Waiver from DOH	Benzene	Ethylbenzene	Monitoring requirement is one sample every six years Waiver from DOH
Beryllium		Bromobenzene	Hexachlorobutadiene	
Cadmium	Sample from 4/5/17	Bromochloromethane	Isopropylbenzene	Sample from 4/5/17
Mercury		Bromomethane	p-Isopropyltoluene	
Silver	<b>Non-Detect</b>	N-Butylbenzene	Methylene Chloride	<b>Non-Detect</b>
Selenium		sec-Butylbenzene	n-Propylbenzene	
Iron	Monitoring requirement is at State discretion Waiver from DOH	Tert-Butylbenzene	Styrene	Sample from 4/5/17
Manganese		Carbon Tetrachloride	1,1,1,2-Tetrachloroethane	
Color	Sample from 4/5/17	Chlorobenzene	1,1,2,2-Tetrachloroethane	<b>Non-Detect</b>
Cyanide		4-Chlorotoluene	Tetrachloroethene	
Odor	<b>Non-Detect</b>	Dibromomethane	Toluene	<b>Non-Detect</b>
Disinfection Byproducts		1,2-Dichlorobenzene	1,2,3-Trichlorobenzene	
		1,3-Dichlorobenzene	1,2,4-Trichlorobenzene	
		1,4-Dichlorobenzene	1,1,1-Trichloroethane	
		Dichlorodifluoromethane	1,1,2-Trichloroethane	
		1,1-Dichloroethane	Trichloroethene	
		1,2-Dichloroethane	Trichlorofluoromethane	
		1,1 Dichloroethene	1,2,3-Trichloropropane	
		cis-1,2 Dichloroethene	1,2,4-Trimethylbenzene	
		Trans-1,2-Dichloroethene	1,3,5-Trimethylbenzene	
		1,2 Dichloropropane	m-Xylene	
		1,3 Dichloropropane	o- Xylene	
		2,2 Dichloropropane	p-Xylene	
		1,1 Dichloropropene	Vinyl Chloride	
		Cis-1,3-Dichloropropene	MTBE	
		E. coli		<b>Non-Detect</b> 4 samples/ month
		<b>Radiological Parameters</b>		
		Gross Alpha-Beta Scan	4/5/17	Monitoring is 1 sample every 6- 9 years
		Radium 226	N/A	<b>Non-Detect</b>
		<b>Synthetic Organic Chemicals (Group I)</b>	<b>Synthetic Organic Chemicals (Group II)</b>	
		Atachlor	Aldicarb	
		Aldicarb Sulfoxide	Aldicarb Sulfone	Monitoring requirement is 1 sample every 18 months; Sample from 9/20/17
		Atrazine	Carbofuran	
		Chlordane	Dibromochloropropane	
		2,4-D	Endrin	
		Ethylene Dibromide	Heptachlor	
		Lindane	Methoxychlor	
		PCB's	Toxaphene	
		2,4,5-TP (Silvex)		<b>Non-Detect</b> <b>*State waiver does not require monitoring these compounds</b>

MT. IDA TABLE OF DETECTED CONTAMINANTS Public Water Supply Identification Number NY1030073						
Contaminant	Violation Y/N	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b> (sample data from 4/5/17 unless otherwise noted)						
Barium	N	77.7	ppb	2000	2000	Geology; Naturally occurring
Chloride	N	44.6	ppm	N/A	250	Geology; Naturally occurring
Chromium	N	2.3	ppb	100	100	Erosion of natural deposits
Copper (samples from 7/9/17) Range of copper concentrations	N	049 <sup>1</sup> 0.06-0.88	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.
Lead	N	9.5 <sup>2</sup> ND-17	ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits
Nickel	N	1.8	ppb	N/A	100	Discharge from steel/metal factories
Nitrate (as Nitrogen) sample from 3/7/18	N	2.59	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.
pH	N	7.49	units		6.5-8.5	
Sodium <sup>3</sup>	N	26.9	ppm	N/A	N/A	Geology; Road Salt
Sulfate	N	44	ppm	N/A	250	Geology;
Zinc	N	13.8	ppb	N/A	5000	Naturally occurring
<b>Disinfection Byproducts</b> (samples from 9/2/15)						
Chlorine (average) Range of chlorine residuals (based on daily samples)	N	0.69 0.004-1.17	ppm	MRDLG N/A	MRDL 4	Used in the treatment and disinfection of drinking water
TTHM[Total Trihalomethanes]	N	15.5	ppb	0	80	By-product of drinking water chlorination
HAA5 [Haloacetic Acids]	N	4.5	ppb	N/A	60	By-product of drinking water chlorination

**NOTES-**

- The level presented represents the 90th percentile of the 5 samples collected. The number represents the average of the two highest levels detected. The action level for copper was not exceeded at any of the 5 sites tested.
- The level presented represents the 90th percentile of the 5 samples collected. The number represents the average of the two highest levels detected. The action level for lead was not exceeded at any of the 5 sites tested.
- Water containing more than 20 mg/l should not be consumed by persons on severely restricted sodium diets.

*Non-Detects (ND)* - laboratory analysis indicates that the constituent is not present.

*Parts per million (ppm) or Milligrams per liter (mg/l)* - one part per million corresponds to one minute in two years or a single penny in \$10,000.

*Parts per billion (ppb) or Micrograms per liter* - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

*90<sup>th</sup> Percentile Value*- The values reported for lead and copper represent the 90<sup>th</sup> percentile. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90<sup>th</sup> percentile is equal to or greater than 90% of the lead and copper values detected at your water system

*Action Level* - the concentration of a contaminant, which, if exceeded, triggers treatment, or other requirements, which a water system must follow.

*Maximum Contaminant Level* - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

*Maximum Contaminant Level Goal* The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

*Maximum Residual Disinfectant Level (MRDL)*: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

*Maximum Residual Disinfectant Level Goal (MRDLG)*: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination

*N/A-Not applicable*

**Appendix A**

New York State Sanitary Code Compliance Monitoring Requirements- Compounds Analyzed that were Below Limits of Detection

TOWN OF GREENPORT TEST RESULTS-SOUTH WELLS Public Water Supply Identification Number NY1000238			
CONTAMINANT	MONITORING FREQUENCY	CONTAMINANT	MONITORING FREQUENCY

**Greenport WD No. 1**  
**NY1000238**  
**Source Water Assessment Summary**

The NYSDOH has completed a source water assessment for this source, based on available information. Possible and actual threats to this drinking water source were evaluated. The state source water assessment includes a susceptibility rating based on the risk posed by each potential source of contamination and how easily contaminants can move through the subsurface to the wells. The susceptibility rating is an estimate of the potential for contamination of the source water, it does not mean that the water delivered to consumers is, or will become contaminated. See section "Are there contaminants in our drinking water?" for a list of the contaminants that have been detected. The source water assessments provide resource managers with additional information for protecting source waters into the future.

As mentioned before, our water is derived from 4-drilled wells. The source water assessment has rated these wells as having high to very high susceptibility to microbials, industrial solvents, nitrates and other industrial contaminants. The wells yield or pump greater than 100 gpm from an unconfined aquifer. Please note that our water is disinfected to ensure that the finished water delivered into your home meets the New York State's drinking water standards for microbial contamination.

County and state health departments will use this information to direct future source water protection activities. These may include water quality monitoring, resource management, planning, and education programs. A copy of the full Source Water Assessment, including a map of the assessment area, is available for review by contacting us at the number provided in this report.


---

**Mount Ida**  
**NY1030073**  
**Source Water Assessment Summary**

The NYSDOH has completed a source water assessment for this source, based on available information. Possible and actual threats to this drinking water source were evaluated. The state source water assessment includes a susceptibility rating based on the risk posed by each potential source of contamination and how easily contaminants can move through the subsurface to the wells. The susceptibility rating is an estimate of the potential for contamination of the source water, it does not mean that the water delivered to consumers is, or will become contaminated. See section "Are there contaminants in our drinking water?" for a list of the contaminants that have been detected. The source water assessments provide resource managers with additional information for protecting source waters into the future.

As mentioned before, our water is derived from a caisson well. The source water assessment has rated this well as having medium to high susceptibility to microbials, nitrates, industrial solvents, and other industrial contaminants. The well draws from an unconfined aquifer with high hydraulic conductivity. Please note that our water is disinfected to ensure that the finished water delivered into your home meets the New York State's drinking water standards for microbial contamination.

County and State health departments will use this information to direct future source water protection activities. These may include water quality monitoring, resource management, planning, and education programs. A copy of the full Source Water Assessment, including a map of the assessment area, is available for review by contacting us at the number provided in this report.



PO BOX 705  
NEWTONVILLE, NY 12128  
(518) 785-9839

**PHASE II AND PHASE V MONITORING**

**SAMPLE INFORMATION**

<b>Sample ID</b>	JH1801580	<b>Customer Code</b>	0702m
<b>Federal Water Supply Code</b>	NY1030073	<b>DOH</b>	Columbia Amy Schober
<b>Water Supply</b>	Town of Greenport, Mt Ida		
<b>Address</b>	Town Hall Drive	, Hudson	, NY , 12534
<b>Sample Location</b>	Entry Point		
<b>Date Collected</b>	3/7/2018	<b>Time Collected</b>	8:17 AM
<b>Sample Collector</b>	Fred Fuchs	<b>E-Mail</b>	GPWGPWS1@MHcable.
<b>Date Printed</b>	3/7/18		

**LABORATORY REPORT**

ANALYTE	CONCENTRATION MG/L	METHOD	MCL *	Date Analyzed	Lab ID Number
<b><u>INORGANICS Table 8C</u></b>					
		set up time			
Nitrate	2.59	12:45	Hach 10206	10 mg/l as N	3/7/2018 11799
Nitrite	NT		EPA 354.1	1 mg/l as N	

Notes:

MCL\* is the Maximum Contaminant Level; it is the maximum concentration allowed in drinking water for a specific analyte as per NYS Sanitary Code. Hold time for nitrate per ELAP requirements is 48 hours for potable, non-chlorinated water samples and 14 days for potable, chlorinated water supplies. Samples for nitrate testing are also required to be received at 4 degrees Celsius or delivered to the laboratory on ice in the chilling process.

Legend: MG/L = Milligrams per Liter; < = Less Than; > = Greater Than;  
mg/L = Parts per million; ug/L = Parts per billion; NT= Not Tested NC = Not Chlorinated

The above test procedures meet all the requirements of NELAC and relate only to these samples





PO BOX 705  
NEWTONVILLE, NY 12128  
(518) 785-9839

**PHASE II AND PHASE V MONITORING**

**SAMPLE INFORMATION**

<b>Sample ID</b>	JH1801581	<b>Customer Code</b>	0702
<b>Federal Water Supply Code</b>	NY1000238	<b>DOH</b>	Columbia Amy
<b>Water Supply</b>	Town of Greenport Water Department		
<b>Address</b>	Town Hall Drive	, Hudson	, NY , 12534
<b>Sample Location</b>	Entry Point		
<b>Date Collected</b>	3/7/2018	<b>Time Collected</b>	7:00 AM
<b>Sample Collector</b>	Fred Fuchs	<b>E-Mail</b>	GPWS1@MHcable.com
<b>Date Printed</b>	3/7/18		

**LABORATORY REPORT**

ANALYTE	CONCENTRATION MG/L	METHOD	MCL *	Date Analyzed	Lab ID Number
<b><i>INORGANICS Table 8C</i></b>					
		set up time			
Nitrate	<0.23	12:45	Hach 10206	10 mg/l as N	3/7/2018 11799
Nitrite	NT		EPA 354.1	1 mg/l as N	

Notes:

MCL\* is the Maximum Contaminant Level; it is the maximum concentration allowed in drinking water for a specific analyte as per NYS Sanitary Code. Hold time for nitrate per ELAP requirements is 48 hours for potable, non-chlorinated water samples and 14 days for potable, chlorinated water supplies. Samples for nitrate testing are also required to be received at 4 degrees Celsius or delivered to the laboratory on ice in the chilling process.

Legend: MG/L = Milligrams per Liter; < = Less Than; > = Greater Than;  
mg/L = Parts per million; ug/L = Parts per billion; NT= Not Tested NC = Not Chlorinated

The above test procedures meet all the requirements of NELAC and relate only to these samples



JH CONSULTING GROUP,  
 INC  
 PO BOX 705  
 NEWTONVILLE, NY 12128  
 (518) 785-9839

**SAMPLE INFORMATION**

<b>Sample ID</b>	JH1807385	<b>Customer Code</b>	0702
<b>Federal Water Supply Code</b>	NY1000238		
<b>Water Supply</b>	Town of Greenport Water Department		
<b>Sample Location</b>	MRT 0001 Dunn Building Supplies, Graham Ave, Hudson, NY 12534		
<b>Date Collected</b>	9/12/2018	<b>Time Collected</b>	9:00 AM
		<b>Free Chlorine</b>	mg/L
<b>Sample Collector</b>	Fred Fuchs		
<b>Date Printed</b>	1/29/2019		

EPA Method 552.2 <b>Haloacetic Acids (HAA5)</b>	Date Analyzed 9/20/2018	NYS Lab ID # 11549
---	-------------------------	--------------------

**RESULTS**

<b>ANALYTE</b>	<b>CONCENTRATION</b>	<b>UG/L</b>	<b>MCL *</b>	<b><u>METHOD</u></b>
Dibromoacetic Acid	<0.50			EPA 552.2
Dichloroacetic Acid	3.3			EPA 552.2
Monobromoacetic Acid	<0.50			EPA 552.2
Monochloroacetic Acid	<0.50			EPA 552.2
Trichloroacetic Acid	8.1			EPA 552.2
Total Haloacetic Acid	11		60 µg/L	

**Notes:**

MCL\* is the Maximum Contaminant Level; In case of HAA5 the running average of the four most recent quarterly monitoring allowed in drinking water for a specific analyte as per NYS Sanitary Code.  
 UG/L is Micrograms per Liter  
 The above test procedures meet all the requirements of NELAC and related only to this sample



**PO BOX 705  
 NEWTONVILLE, NY 12128  
 (518) 785-9839**

***SAMPLE INFORMATION***

<b>Sample ID</b>	JH1801583	<b>Customer Code</b>	0702
<b>Federal Water Supply Code</b>	NY1000238	<b>DOH</b>	Columbia Amy
<b>Water Supply</b>	Town of Greenport Water Department		
<b>Address</b>	Town Hall Drive , Hudson , NY , 12534		
<b>Sample Location</b>	Entry Point		
<b>Dates Collected</b>	3/7/2018		
<b>Sample Collector</b>	Fred Fuchs		
<b>Date Printed</b>	1/29/2019		
<b>Date Entered</b>	4/7/2018		

**LABORATORY REPORT**

<b>ANALYTE</b>	<b>CONCENTRATION pCi/L</b>	<b>Test method</b>	<b>Date Analyzed</b>	<b>MCL *</b>	<b>NYS LAB #</b>
Gross Alpha, total				15 (including Radium 226 but excluding radon and uranium)	
Gross Alpha, total, error, +/-					
Gross Alpha, total, LLD				( Beta particle and photon radioactivity	
Gross Beta, total				Four millirems per year as the annual dose equivalent to the total body or any internal organ. Health Dept. to determine concentration capable of producing four millirems per year)	
Gross Beta, total, error, +/-					
Gross Beta, total, LLD					
Radium 226, total	U 0.09	EPA 903.0	3/30/2018		10861
Radium 226, total, error +/-	0.1				
Carrier Recovery 226	89%				
Radium 226, total, LLD	0.1				
Radium 228, total	1.57	EPA 904.0	3/30/2018	5 (combined Radium 226 & 228)	10861
Radium 228, total, error +/-	0.88				
Carrier Recovery 228	87%				
Radium 228, total, LLD	0.75				

Notes:


**U = Indicates the compound was analyzed for but not detected above the detection limit**

MD- LLD over-range due to high solids content

NT= Not Tested

The above test procedures meet all the requirements of NELAC and relate only to this sample

pCi/L= picocuries per liter  
 ND = Not detected at level in limits column  
 LLD = Lower limit of detection



JH CONSULTING GROUP,  
INC  
PO BOX 705  
NEWTONVILLE, NY 12128  
(518) 785-9839

**SAMPLE INFORMATION**

<b>Sample ID</b>	JH1808096	<b>Supply Code</b>	0702
<b>Federal Water Supply Code</b>	NY1000238		
<b>Public Water Supply</b>	Town of Greenport Water Department		
<b>Address</b>	Town Hall Drive	<b>City</b>	Hudson
		<b>State</b>	NY
		<b>Zip</b>	12534
<b>Sample Location</b>	MRT 0001 Dunn Building Supplies, Graham Ave, Hudson, NY 12534		
<b>Date Collected</b>	10/3/2018	<b>Time Collected</b>	10:05 AM
		<b>Free Chlorine</b>	0.24 mg/L
<b>Sample Collector</b>	Fred Fuchs		
<b>Date Printed</b>	10/24/2018		

<b>EPA METHOD 524.2 Trihalomethanes (THM's)</b>	<b>Date Analyzed</b>	10/23/18	<b>NYS Lab</b>	10350
---	----------------------	----------	----------------	-------

<b>ANALYTE</b>	<b>CONCENTRATION UG/L</b>	<b>MCL*</b>	<b><u>METHOD</u></b>
Chloroform	6.6		EPA 524.2
Bromodichloromethane	5.0		EPA 524.2
Chlorodibromomethane	2.7		EPA 524.2
Bromoform	<1.0		EPA 524.2
Total Trihalomethane	14.3	80 ug/l	

Notes:

MCL\* is the Maximum Contaminant Level; A violation of the MCL occurs if the Locational Running Annual Average of the four most samples, by location, exceeds the MCL.

The above test procedures meet all the requirements of NELAC and related only to this sample

The surrogate recoveries for 4-fluorobenzene and 1,2-Dichlorobenzene-d4 for this sample were within acceptance limits at 98 and 103% respectively. The acceptable limits are 80-120%. A trip blank did not accompany this sample.